

43 Lord Street, Millom, Cumbria LA18 4BN

Proposal for sound insulation between properties being converted back to two properties as taken from email:

Hi Demi,

Hope you're well.

I have spoken to the builder and it was his intention to brick the door ways up then "dot and dab" acoustic plasterboards on both sides, before plastering.

As I mentioned yesterday, the property was previously two separate houses so we would effectively be restoring it to how it was initially, with the benefit of the acoustic plasterboards.

Please see attached below current plan.

If you require any further information, please let me know.

Many thanks,

*Kyle*

Also attached is proposed floorplan with new seperating areas marked up.