

Joy F. Bain

From: Environmental Health
Sent: 04 September 2026 15:57
To: Development Control
Cc: Christie Burns
Subject: 4/2/2175/0F1 - GHYLL HOUSE FARM, EGREMONT

Categories: Red Category

Conversion of existing hayloft and demolition and replacement of single storey building to form an extension to the existing dwelling house

Thank you for the above planning consultation.

There are no objections from Environmental Health to the proposed amendments to this application.
We would advise, however, that rainwater drainage should not be directed to the septic tank, as it may have the effect of flushing out the tank during heavy rainfall and compromising the treatment of foul waste in the tank.

Regards

Environmental Health
Public Health & Protection | Cumberland Council
Whitehaven Commercial Park, Moresby Parks, Whitehaven, Cumbria, CA28 8YD

T. 0300 373 3730

cumberland.gov.uk

