

Photographic Schedule

OB-06 / P01 | Revision 01 | 6 September 2026

Listed Building Consent + Householder Planning Permission

P01 - Rear terrace context



No. 3: supplied identification

The supplied yellow/red highlight identifies No. 3 in the rear context. It is not a boundary survey. Neighbouring windows are relevant to visual and acoustic assessment.

Source: applicant-supplied image; capture date not established. Original highlights/overlays preserved. Added teal leader is indicative only. Photograph is not to scale; do not measure from it.

Photographic Schedule

OB-06 / P02 | Revision 01 | 6 September 2026

Listed Building Consent + Householder Planning Permission

P02 - Courtyard outdoor-unit area



AC-OU01: indicative ground-level area

AC-OU01 is proposed at ground level in the highlighted courtyard area on independent anti-vibration supports. The highlight is not an equipment footprint. Confirm wall/window distances, airflow and access after removal of temporary obstructions.

Source: applicant-supplied image; capture date not established. Original highlights/overlays preserved. Added teal leader is indicative only. Photograph is not to scale; do not measure from it.

Photographic Schedule

OB-06 / P03 | Revision 01 | 6 September 2026

Listed Building Consent + Householder Planning Permission

P03 - Rear elevation and office window



Office window: contextual reference

The applicant identifies the upper highlighted window as the office window. The indoor unit is on the opposite internal wall, not on this window wall. Survey the full internal route to a discreet rear service entry and external descent.

Source: applicant-supplied image; capture date not established. Original highlights/overlays preserved. Added teal leader is indicative only. Photograph is not to scale; do not measure from it.

Photographic Schedule

OB-06 / P04 | Revision 01 | 6 September 2026

Listed Building Consent + Householder Planning Permission

P04 - Office shared-wall unit



AC-IU01: shared-wall plain area

AC-IU01 is proposed on the shared wall above the noticeboard area, opposite the rear window. The small highlighted area at the far right is not a third unit. Final location must align with the bedroom unit and avoid all mouldings/architraves.


Source: applicant-supplied image; capture date not established. Original highlights/overlays preserved. Added teal leader is indicative only. Photograph is not to scale; do not measure from it.

Photographic Schedule

OB-06 / P05 | Revision 01 | 6 September 2026

Listed Building Consent + Householder Planning Permission

P05 - Bedroom shared-wall unit



Retain moulding: highlight is not a footprint

AC-IU02 is immediately behind AC-IU01 on the other face of the same wall. The supplied highlight crosses the horizontal moulding: that full highlighted zone must NOT be used as the unit outline. Measure a plain area accommodating the 295 mm unit height plus manufacturer clearances; retain cornice and rail.

Source: applicant-supplied image; capture date not established. Original highlights/overlays preserved. Added teal leader is indicative only. Photograph is not to scale; do not measure from it.