

From: Environmental Health
Sent: 12 August 2026 11:46
To: Development Control
Cc: Christie Burns
Subject: 4/26/2255/0B1 - NEW HOUSE FARM, DRIGG

Variation of condition 2 (plans) of planning application 4/26/2048/0R1 – Application for approval of reserved matters relating to appearance, landscaping, layout and scale pursuant to outline planning approval 4/24/2281/0O1

Thank you for the above planning consultation.

There are no objections to this proposed development from Environmental Health.
It would be helpful if the following information is provided:

- A MCS 020 (a) noise assessment for the ASHP – this is to ensure its predicted noise level at 1m perpendicular to the nearest door / window of a habitable room of the closest dwelling (Lea Croft in this case) is no greater than 37 dB(A) LA eq (5 mins);
- Confirmation of where the foul effluent from the package treatment plant will be discharged to.

Many thanks.

Environmental Health
Public Health & Protection | Cumberland Council
Whitehaven Commercial Park, Moresby Parks, Whitehaven, Cumbria, CA28 8YD

T. 0300 373 3730

cumberland.gov.uk

