

Copeland area Planning Department, Cumberland Council

For the attention of Planning Officer

Date: 9 December 2024

Your reference: 4/24/2399/0F1

Dear Planning Officer

CONSULTATION ON PLANNING APPLICATION

Appn: 4/24/2399/0F1
Site Address: 7 STATION ROAD, DRIGG
**Proposal: ADDITION OF A DRIVEWAY AND PAVEMENT CROSSING FOR
DISABILITY ACCESS**

Thank you for your consultation on the above Planning Application.

Cumberland Council as the Local Highway Authority (LHA) and Lead Local Flood Authority (LLFA) can confirm as follows:

Further information is required for the following:

Visibility Splays.

The applicant needs to supply a scaled plan showing what the visibility splays are for the proposed access, in this area 43m x 2.4m measured to the nearside kerb/verge in both directions.

Upon receipt of the above information I will be able to provide a further response.

Yours sincerely

Natalie Robinson
Planning Application Officer